



PH. (843) 918-1192

FAX (843) 918-1204

City of Myrtle Beach
SOUTH CAROLINA
FIRE DEPARTMENT

PRECONSTRUCTION MEETING CHECK LIST

- 1) **For all emergencies dial 911.**
- 2) **Provide and maintain a hard surface access road into the property. This access road need not be paved but shall be able to withstand loads imposed upon it by emergency equipment. The road shall extend from a public road onto the project site and give clear access to all buildings.**
- 3) **Provide an adequate number of portable fire extinguishers on the job. Minimum size to be a 10 lb. ABC rated fire extinguisher. Number of extinguishers will be determined by the size of the project.**
- 4) **Combustible construction debris shall not be allowed to collect excessively on the job site. Regular trash removals are to be performed.**
- 5) **Multi-story buildings shall have a construction standpipe installed when construction reaches 50 feet or six levels above grade. The standpipe shall be located at a usable stair.**
- 6) **Buildings requiring sprinkler systems shall have that system installed and operational prior to furniture being brought in to the building.**
- 7) **All building fire alarm and building sprinkler systems work shall be done by a company licensed by the State of South Carolina.**